



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of the BACnet Manufacturers Association (BMA). BTL is a registered trademark of the BMA.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BMA website.

Listing Information

Vendor Andover Controls Corporation One High Street North Andover, Massachusetts 01845 www.andovercontrols.com		Listing Status Listed Product
Test Requirements Requirements as of May 2005	BACnet Protocol Revision 135-2001b	Date Tested May 2005

Product Name	Model Number	Software Version
b3920	b3920	4.300034 Firmware
b3800	b3800	4.300034 Firmware
b3804	b3804	4.300034 Firmware
b3810	b3810	4.300034 Firmware
b3814	b3814	4.300034 Firmware
b3865	b3865	4.300034 Firmware
b3866	b3866	4.300034 Firmware
b3867	b3867	4.300034 Firmware
b3850	b3850	4.300034 Firmware
b3851	b3851	4.300034 Firmware
b3853	b3853	4.300034 Firmware
b3608	b3608	4.300034 Firmware
b3624	b3624	4.300034 Firmware
b3885	b3885	4.300034 Firmware
b3887	b3887	4.300034 Firmware

Product Name	Link to PICS on BMA Website
b3920	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3800	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3804	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3810	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3814	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3865	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3866	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3867	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3850	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3851	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3853	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3608	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3624	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3885	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm
b3887	http://bacnetassociation.org/BMAProductCatalog/TourAn doverControls/index.htm

Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	b3920, b3800, b3804, b3810, b3814, b3865, b3866, b3867, b3850, b3851, b3853, b3608, b3624, b3885, b3887

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Information B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-State Input	Multi-State Output	Multi-State Value
Calendar	Command	Device
Event Enrollment	Loop	Notification Class
Program	Schedule	Trend Log

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4
